

Project theme name: ИРХ №АР09058186. «Methodology development and computer program for determining additional electrical energy losses during its transportation and distribution in the electrical grid.».

Relevance: The operating conditions of power supply systems are changing rapidly. This is due to changes both on the power supply side and on the load side. The stable operation of the power supply system is based on mathematical models and operating rules. Under changing conditions, there is a likelihood of an inadequate description of the situation and, accordingly, erroneous operation of electrical equipment and the power supply system as a whole. To prevent this situation, it is necessary to check the parameters of the regime and the applied calculation methods for adequacy.

The most important criterion for the operation of the power supply system is the level of electricity losses. Under changing conditions, the magnitude and components of electricity losses change. In the current situation, it is necessary to analyze these processes and make adjustments to the applied models.

For this study, it is envisaged to conduct: a review of documentation on the calculation of energy losses; instrumental studies of mode parameters; analysis of applied methods for calculating electricity losses; consideration of influencing factors on the magnitude and components of energy losses. Based on the results of the formation of the database by mathematical methods, their processing is envisaged to obtain dependencies on factors affecting the level of energy losses.

The end result will be the development of an improved model for calculating electricity losses and a computer program for calculating typical cases, it is also envisaged to introduce them into educational and production processes..

The object of research is 110 kV electrical networks.

The purpose of the work is to create an improved methodology for determining the added power losses caused by asymmetry and non-sinusoidal currents in the ES, as well as its implementation in a software environment.

Research methods. In the course of research were used: the theory of matrix calculus, methods and techniques of mathematical modelling, methods of physical and computational experiments, comparison of the results of instrumental surveys with the results of calculations. Synthesis of the results of theoretical and experimental studies will make it possible to assess the adequacy of the adopted solutions, reliability of the obtained results. Conducting instrumental measurements of mode parameters: voltage and current (RMS, AC + DC, peak, fundamental frequency); frequency (at 50 Hz); power (VA, V_{Areact}); power factor; current and voltage harmonics.

As a result of the research, a software application was developed to estimate power losses due to asymmetry and non-sinusoidality of currents. The "Instruction on Loss Calculation for Electric Grid Companies on the Use of the Programme "Calculation of Losses on Power Transmission Lines" was developed. On the basis of the methodology for calculating basic and incremental losses, recommendations were developed, which set out the accounting of incremental losses in the regulation of commercial relations between the power supplying organisation and the consumer, recommendations for assessing incremental losses

of electricity and their accounting in the formation of tariffs, as well as recommendations for reducing the share of incremental losses of electricity. Educational and methodical manuals for implementation in the educational process have been developed.

Degree of implementation. The obtained results are used at network enterprises for processing the results of instrumental survey during energy audit.

Scope of application. Electricity grid companies to determine the structure of losses and assess their quantitative characteristics.

Члены исследовательской группы:

1) **Zhantlessova Assemgul Beisembayevna** (26.12.1982) - head, PhD "electric power engineering". Participates in the preparation of a utility model and development of a computer program for calculating the main and additional losses of electricity from non-symmetry and non-sinusoidality in power supply systems, in project risk assessment, preparation and publication of articles. Author ID: 57195505692. ORCID icon <http://orcid.org/0000-0003-3730-0579>. h-index=3. A total of 41, 7 copyright certificates, patents, 4 of which are published in Thomson Reuters.

2) **Akimzhanov Temirbolat Baltabayevich**-performer, PhD "electric power". In the project, he develops a utility model and a computer program for calculating losses of automatic reactive power compensation devices, prepares methodological guidelines for the developed program, prepares articles and reports, and participates in conferences. Certified energy auditor, is the head of the center for "energy Conservation and dissemination of knowledge". Author ID: 56485979700. the h-index:2.

3) **Zhumazhanov Serik Karatayevich**-candidate of technical Sciences "Eletrotechnical complexes and systems". In the project, he develops a utility model and a computer program for calculating the main and additional losses of electricity from asymmetry and non-sinusoidality in power supply systems, prepares methodological guidelines for the developed program, implements project developments, prepares articles and reports, and participates in conferences. Author ID: 54950223000. h-index: 2.

4) **Yermek Zhaslanovich Sarsikeev** (26.02.1987) - PhD "Electric power engineering". In the project, he is preparing a utility model and a computer program for calculating the main and additional losses of electricity from asymmetry and non-sinusoidality in power supply systems in engines, pumps and fans, and writing a methodological guide to the developed program, implementing developments on the project, preparing articles and reports, participating in conferences. Author ID: 56252099900. ORCID icon <http://orcid.org/0000-0002-7209-5024>. h-index: 5.

5) **Zhanat Beisembayevich Issabekov**- PhD "Electric power engineering". In the project, he develops a utility model and a computer program for calculating the main and additional losses of electricity from non-symmetry and non-sinusoidality in power supply systems in transformer substations, prepares methodological guidelines for the developed program, implements project

developments, prepares articles and reports, and participates in conferences. Author ID: 57194215799. h-index: 2.

6) Issabekova Bibigul Beisembayevna- PhD "Electric power". In the project, he prepares a utility model and a computer program for calculating the main and additional losses of electricity, grounding the neutral of electric networks and implementing developments on the project, preparing articles and reports, participating in conferences. Author ID: 56826203500.

7) Amir Yerlan Kamalievich- master's degree. In the project, he develops a utility model and a computer program for calculating the main and additional losses of electricity from asymmetry and non-sinusoidality in power supply systems, implements project developments, prepares articles and reports, and participates in conferences.

Information for potential users:

As a result of the work carried out, a method for calculating electricity losses will be developed, taking into account the influence of asymmetry and non-sinusoidality, implemented in the form of a computer program and a training manual for implementation in the educational process, as well as instructions for implementation in power grid and other organizations.

List of published works

In 2021:

1. Issabekova B., Tokombaev M., Zhantlessova A. Reed Switch Protection Devices with Symmetric Component Filter without Current Transformers //2021 International Ural Conference on Electrical Power Engineering (UralCon). – IEEE, 2021. – C. 141-146. (in English)

2. Zhantlesova A.B. Elektr zhabdyktaryn paidalanu, diagnostikalau zәne zhondeyu: oku kuraly / Zhantlesova A.B. - Nur-Sultan: S. Seifullin atyndagy Kazak Agrotechnical Universityinni baspasy, 2021. – 220б. (in Kazakh)

In 2022:

3. Isabekov J.B., Isabekova B.B., Zhantlesova A.B., Zhalmagambetova U. K., Commercial losses of electric energy in distribution electric networks // Bulletin of Toraigyrov University. Energy Series. - 2022 - № 3. - C. 70-79. - URL: <https://doi.org/10.48081/JTDY1576> (in Russian)

4. Isabekov J.B., Isabekova B.B., Zhantlesova A.B., Akayev A. M., Ordabaev M. E. Technical losses in distribution electrical networks // Vestnik Toraigyrov University. Energy Series. - 2022. - № 4. - C. 97-111. - URL: doi.org/10.48081/WBBT1581 (in Russian)

5. Akimzhanov T.B., Zhantlesova A.B., Isabekova B.B., Zhumazhanov S.K., Sarsikeev E.J., Isabekov J.B., Amir E.K. Instrumental energy audit: textbook. - Astana: S. Seifullin KazATU Publishing House, 2022 - 35 p. (in Russian)

6. Akimzhanov T.B., Zhantlesova A.B., Isabekova B.B., Zhumazhanov S.K., Sarsikeev E.J., Isabekov J.B., Amir E.K. Aspatyk energy audit: oku adistemelik kuraly. - Astana, S. Seifullin atyndagy Kazak agrotechnical universityininі baspasy, 2022. - 33b (in Kazakh)

In 2023:

7. Zhantlessova, A., Zhumazhanov, S., Akimzhanov, T., Issabekova, B., Issabekov, Z., Mekhtiyev, A., & Neshina, Y.. Instrumental Research on the Voltage Harmonic Distortion Coefficient in the Modern 110 kV Urban Electric Network. *International Journal on Energy Conversion (IRECON)*, - 2023 - № 11(2), C. 56. - URL: <https://doi.org/10.15866/irecon.v11i2.22979>, percentile - 52. (in English)

8. Zhantlessova, A.B., Zhumazhanov, S.K., Akimzhanov, T.B., Mekhtiyev, A.D., Alkina, A.D., Improving the method of controlling the stress-strain state of steel structures of electromechanical systems // *Metalurgija*. – 2023. – Т. 62. – №. 2. – С. 303-305, , процентиль - 35. (in English)

9. Akimzhanov T.B., Zhantlesova A.B., Zhumazhanov S.K., Sarsikeev E.J., Isabekova B.B., Isabekov J.B. Recommendations for accounting of added losses // recommendations. - Astana: S. Seifullin KazATIU Publishing House, 2023 - 14 p. (in Russian)

10. Zhantlesova A.B., Isabekova B.B., Isabekov J.B. Operation, diagnostics and repair of electrical equipment: textbook / Zhantlesova A.B., Isabekova B.B., Isabekov J.B.; Kazakh Agrotechnical Research University named after S.Seyfullin. - Astana: Izd-vo Kazakh Agrotechnical Research University named after S.Seyfullin, 2023. - 225 с. (in Russian)


11. Akimzhanov T.B., Zhumazhanov S.K., Sarsikeev E.J., Isabekov J.B., Amir E.K., Additive losses of electrical energy during its distribution in the electrical network. // *Bulletin of Toraigyrov University. Energy Series*. - 2023. - № 4. - С. 23-35. - <https://vestnik-energy.tou.edu.kz/storage/journals/172.pdf> (in Russian)



12. Akimzhanov, T., Sarsikeev, Y., Zhantlessova, A., Zhumazhanov, S., Baydulla, Z., Issabekova, B., Issabekov, Z., Mekhtiyev, A., & Neshina, Y. (2023). Identifying the influence of the system and mode characteristics on the power loss mode based in 110 kV power grids. *Eastern-European Journal of Enterprise Technologies*, 6(8 (126), 6–14. <https://doi.org/10.15587/1729-4061.2023.292253>, percentile - 39. (in English)


Results

1. The developed software application that allows to estimate power losses from asymmetry and non-sinusoidality of currents (the certificate of inclusion of information in the state register of copyrighted objects No. 29086-1 dated 5 October 2022 was obtained). This software application allows to calculate power losses when taking into account asymmetry and non-sinusoidality of currents, can also be used in the processing of the results of instrumental energy surveys of overhead lines of power systems, in the study of voltage and current patterns, levels of added losses depending on the dimensions of supports, wires and cables. When assessing the level of additive losses in the network, a sufficient number of overhead lines surveyed for this purpose is established based on the results of a









Power Log 5.8 - [AERLEV - Карта SD.fprfo]

Файл Правка Вид Инструменты Окно Справка

От 30.11.2020 12:23 до 01.12.2020 05:11		События по СКВ №11: СКВ 02.12.2020 2:54:59 361 мсек											
Дата	Функция	AN(V) / A(A) Min	AN(V) / A(A) Max	AN(V) / A(A) Avg	BN(V) / B(A) Min	BN(V) / B(A) Max	BN(V) / B(A) Avg	BN(V) / B(A) Min	BN(V) / B(A) Max	BN(V) / B(A) Avg	CN(V) / C(A) Min	CN(V) / C(A) Max	CN(V) / C(A) Avg
30.11.2020 12:23:55 409мсек	Уptime рн-рн	126,139 кВ (f)	128,238 кВ (f)	128,37 кВ (f)	128,524 кВ (f)	128,755 кВ (f)	129,063 кВ (f)	128,106 кВ (f)	128,227 кВ (f)	128,403 кВ (f)	128,106 кВ (f)	128,227 кВ (f)	128,403 кВ (f)
30.11.2020 12:23:55 409мсек	Напряжение оcn. частоты	73,92 кВ (f)	73,92 кВ (f)	74,03 кВ (f)	74,14 кВ (f)	74,25 кВ (f)	74,36 кВ (f)	74,14 кВ (f)	74,25 кВ (f)	74,36 кВ (f)	74,14 кВ (f)	74,25 кВ (f)	74,36 кВ (f)
30.11.2020 12:23:55 409мсек	Ток оcn. частоты	100 А (f)	100 А (f)	200 А (f)	100 А (f)	100 А (f)	100 А (f)	100 А (f)	200 А (f)	100 А (f)	100 А (f)	100 А (f)	200 А (f)
30.11.2020 12:23:55 409мсек	РН напряжения	0 ε	0 ε	0 ε	-119,96 ε	-119,96 ε	-119,96 ε	-240,18 ε	-240,18 ε	-240,18 ε	-240,18 ε	-240,18 ε	-240,18 ε
30.11.2020 12:23:55 409мсек	РН тока	-30,86 ε	-27,12 ε	-23,58 ε	-120,72 ε	-115,04 ε	-106,7 ε	-269,18 ε	-264,96 ε	-264,96 ε	-264,96 ε	-264,96 ε	-264,96 ε
30.11.2020 12:23:55 409мсек	Аmps	150 А (f)	150 А (f)	200 А (f)	150 А (f)	150 А (f)	200 А (f)	150 А (f)	200 А (f)	150 А (f)	150 А (f)	200 А (f)	200 А (f)
30.11.2020 12:23:55 409мсек	ТНД напряжения	0,67 % (f)	0,69 % (f)	0,71 % (f)	0,75 % (f)	0,75 % (f)	0,75 % (f)	0,81 % (f)	0,68 % (f)	0,72 % (f)	0,75 % (f)	0,75 % (f)	0,75 % (f)
30.11.2020 12:23:55 409мсек	ТНД тока	6,72 % (f)	9,86 % (f)	20,67 % (f)	2,96 % (f)	6,72 % (f)	15,67 % (f)	7,65 % (f)	10,1 % (f)	15,58 % (f)	10,1 % (f)	15,58 % (f)	15,58 % (f)
30.11.2020 12:23:55 409мсек	К-фактор А	1,54 (f)	1,52 (f)	2,99 (f)	1,58 (f)	1,58 (f)	2,62 (f)	1,42 (f)	1,62 (f)	2,25 (f)	1,62 (f)	2,25 (f)	2,25 (f)
30.11.2020 12:23:55 409мсек	ТНД мощности	0,01 % (f)	0,03 % (f)	0,08 % (f)	0 % (f)	0,01 % (f)	0,05 % (f)	0,02 % (f)	0,03 % (f)	0,05 % (f)	0,03 % (f)	0,05 % (f)	0,05 % (f)
30.11.2020 12:23:55 409мсек	К-фактор W	0,99 (f)	1 (f)	1,02 (f)	0,98 (f)	1 (f)	1,02 (f)	0,99 (f)	1,01 (f)	1,02 (f)	1,01 (f)	1,02 (f)	1,02 (f)
30.11.2020 12:23:55 409мсек	Частота	49,984 Hz (f)	49,995 Hz (f)	50,026 Hz (f)	50,026 Hz (f)	50,026 Hz (f)	50,026 Hz (f)	50,026 Hz (f)	50,026 Hz (f)	50,026 Hz (f)	50,026 Hz (f)	50,026 Hz (f)	50,026 Hz (f)
30.11.2020 12:24:55 409мсек	Уptime рн-рн	128,172 кВ (f)	128,359 кВ (f)	128,458 кВ (f)	128,788 кВ (f)	128,876 кВ (f)	129,041 кВ (f)	128,161 кВ (f)	128,304 кВ (f)	128,414 кВ (f)	128,161 кВ (f)	128,304 кВ (f)	128,414 кВ (f)
30.11.2020 12:24:55 409мсек	Напряжение оcn. частоты	73,92 кВ (f)	74,03 кВ (f)	74,03 кВ (f)	74,25 кВ (f)	74,36 кВ (f)	74,36 кВ (f)	74,25 кВ (f)	74,36 кВ (f)	74,25 кВ (f)	74,25 кВ (f)	74,36 кВ (f)	74,36 кВ (f)
30.11.2020 12:24:55 409мсек	Ток оcn. частоты	100 А (f)	100 А (f)	100 А (f)	100 А (f)	100 А (f)	100 А (f)	100 А (f)	100 А (f)	100 А (f)	100 А (f)	100 А (f)	200 А (f)
30.11.2020 12:24:55 409мсек	РН напряжения	0 ε	0 ε	0 ε	-119,92 ε	-119,82 ε	-119,82 ε	-240,18 ε	-240,18 ε	-240,18 ε	-240,18 ε	-240,18 ε	-240,18 ε
30.11.2020 12:24:55 409мсек	РН тока	-30,34 ε	-27,04 ε	-23,08 ε	-119,96 ε	-114,66 ε	-105,2 ε	-269,96 ε	-264,96 ε	-264,96 ε	-264,96 ε	-264,96 ε	-264,96 ε
30.11.2020 12:24:55 409мсек	Аmps	150 А (f)	150 А (f)	200 А (f)	150 А (f)	150 А (f)	250 А (f)	150 А (f)	150 А (f)	200 А (f)	150 А (f)	200 А (f)	200 А (f)
30.11.2020 12:24:55 409мсек	ТНД напряжения	0,67 % (f)	0,7 % (f)	0,74 % (f)	0,75 % (f)	0,8 % (f)	0,67 % (f)	0,67 % (f)	0,7 % (f)	0,7 % (f)	0,7 % (f)	0,7 % (f)	0,73 % (f)
30.11.2020 12:24:55 409мсек	ТНД тока	6,87 % (f)	9,95 % (f)	17,62 % (f)	3,48 % (f)	6,11 % (f)	25,02 % (f)	7,65 % (f)	10,21 % (f)	14,94 % (f)	10,21 % (f)	14,94 % (f)	14,94 % (f)
30.11.2020 12:24:55 409мсек	К-фактор А	1,55 (f)	1,86 (f)	2,42 (f)	1,51 (f)	1,75 (f)	3,01 (f)	1,46 (f)	1,66 (f)	2,07 (f)	1,66 (f)	2,07 (f)	2,07 (f)
30.11.2020 12:24:55 409мсек	ТНД мощности	0,01 % (f)	0,03 % (f)	0,09 % (f)	0 % (f)	0,01 % (f)	0,06 % (f)	0,01 % (f)	0,02 % (f)	0,01 % (f)	0,02 % (f)	0,05 % (f)	0,05 % (f)
30.11.2020 12:24:55 409мсек	К-фактор W	0,98 (f)	1 (f)	1,02 (f)	0,99 (f)	1 (f)	1,01 (f)	1 (f)	1,01 (f)	1,01 (f)	1,01 (f)	1,02 (f)	1,02 (f)
30.11.2020 12:24:55 409мсек	Частота	50,013 Hz (f)	50,023 Hz (f)	50,033 Hz (f)	50,033 Hz (f)	50,033 Hz (f)	50,033 Hz (f)	50,033 Hz (f)	50,033 Hz (f)	50,033 Hz (f)	50,033 Hz (f)	50,033 Hz (f)	50,033 Hz (f)
30.11.2020 12:25:55 409мсек	Уptime рн-рн	128,161 кВ (f)	128,26 кВ (f)	128,37 кВ (f)	128,81 кВ (f)	128,92 кВ (f)	129,019 кВ (f)	128,216 кВ (f)	128,337 кВ (f)	128,436 кВ (f)	128,216 кВ (f)	128,337 кВ (f)	128,436 кВ (f)
30.11.2020 12:25:55 409мсек	Напряжение оcn. частоты	73,92 кВ (f)	73,92 кВ (f)	74,03 кВ (f)	74,25 кВ (f)	74,25 кВ (f)	74,36 кВ (f)	74,25 кВ (f)	74,36 кВ (f)	74,36 кВ (f)	74,36 кВ (f)	74,36 кВ (f)	74,36 кВ (f)
30.11.2020 12:25:55 409мсек	Ток оcn. частоты	100 А (f)	100 А (f)	200 А (f)	100 А (f)	100 А (f)	100 А (f)	100 А (f)	100 А (f)	100 А (f)	100 А (f)	100 А (f)	200 А (f)
30.11.2020 12:25:55 409мсек	РН напряжения	0 ε	0 ε	0 ε	-119,88 ε	-119,8 ε	-119,74 ε	-240,18 ε	-240,18 ε	-240,18 ε	-240,18 ε	-240,18 ε	-240,18 ε
30.11.2020 12:25:55 409мсек	РН тока	-30,98 ε	-27,26 ε	-24,02 ε	-122,34 ε	-114,66 ε	-108,84 ε	-270,1 ε	-264,96 ε	-264,96 ε	-264,96 ε	-264,96 ε	-264,96 ε
30.11.2020 12:25:55 409мсек	Аmps	150 А (f)	150 А (f)	300 А (f)	100 А (f)	150 А (f)	200 А (f)	150 А (f)	150 А (f)	200 А (f)	150 А (f)	200 А (f)	200 А (f)
30.11.2020 12:25:55 409мсек	ТНД напряжения	0,60 % (f)	0,73 % (f)	0,76 % (f)	0,78 % (f)	0,82 % (f)	0,65 % (f)	0,7 % (f)	0,74 % (f)	0,77 % (f)	0,74 % (f)	0,77 % (f)	0,77 % (f)
30.11.2020 12:25:55 409мсек	ТНД тока	6,94 % (f)	9,93 % (f)	28,37 % (f)	3,5 % (f)	6,59 % (f)	14,88 % (f)	7,87 % (f)	10,41 % (f)	16,03 % (f)	10,41 % (f)	16,03 % (f)	16,03 % (f)
30.11.2020 12:25:55 409мсек	К-фактор А	1,45 (f)	1,86 (f)	3,73 (f)	1,56 (f)	1,88 (f)	2,3 (f)	1,48 (f)	1,72 (f)	2,16 (f)	1,72 (f)	2,16 (f)	2,16 (f)
30.11.2020 12:25:55 409мсек	ТНД мощности	0,02 % (f)	0,03 % (f)	0,14 % (f)	0 % (f)	0,02 % (f)	0,04 % (f)	0,01 % (f)	0,03 % (f)	0,03 % (f)	0,03 % (f)	0,08 % (f)	0,08 % (f)
30.11.2020 12:25:55 409мсек	К-фактор W	0,99 (f)	1 (f)	1,02 (f)	0,99 (f)	1 (f)	1,01 (f)	1 (f)	1,01 (f)	1,01 (f)	1,01 (f)	1,02 (f)	1,02 (f)
30.11.2020 12:25:55 409мсек	Частота	50,019 Hz (f)	50,024 Hz (f)	50,031 Hz (f)	50,031 Hz (f)	50,031 Hz (f)	50,031 Hz (f)	50,031 Hz (f)	50,031 Hz (f)	50,031 Hz (f)	50,031 Hz (f)	50,031 Hz (f)	50,031 Hz (f)
30.11.2020 12:26:55 409мсек	Уptime рн-рн	127,996 кВ (f)	128,117 кВ (f)	128,249 кВ (f)	128,678 кВ (f)	128,843 кВ (f)	128,964 кВ (f)	128,139 кВ (f)	128,271 кВ (f)	128,381 кВ (f)	128,139 кВ (f)	128,271 кВ (f)	128,381 кВ (f)
30.11.2020 12:26:55 409мсек	Напряжение оcn. частоты	73,81 кВ (f)	73,92 кВ (f)	73,92 кВ (f)	74,14 кВ (f)	74,25 кВ (f)	74,36 кВ (f)	74,25 кВ (f)	74,36 кВ (f)	74,36 кВ (f)	74,36 кВ (f)	74,36 кВ (f)	74,36 кВ (f)
30.11.2020 12:26:55 409мсек	Ток оcn. частоты	100 А (f)	100 А (f)	200 А (f)	100 А (f)	100 А (f)	100 А (f)	100 А (f)	100 А (f)	100 А (f)	100 А (f)	100 А (f)	200 А (f)
30.11.2020 12:26:55 409мсек	РН напряжения	0 ε	0 ε	0 ε	-119,8 ε	-119,78 ε	-119,74 ε	-240,18 ε	-240,18 ε	-240,18 ε	-240,18 ε	-240,18 ε	-240,18 ε
30.11.2020 12:26:55 409мсек	РН тока	-30,88 ε	-27,26 ε	-23,98 ε	-120,66 ε	-114,76 ε	-109,3 ε	-264,74 ε	-264,96 ε	-264,96 ε	-264,96 ε	-264,96 ε	-264,96 ε
30.11.2020 12:26:55 409мсек	Аmps	150 А (f)	150 А (f)	200 А (f)	150 А (f)	150 А (f)	150 А (f)	150 А (f)	150 А (f)	200 А (f)	150 А (f)	200 А (f)	200 А (f)
30.11.2020 12:26:55 409мсек	ТНД напряжения	0,69 % (f)	0,75 % (f)	0,77 % (f)	0,79 % (f)	0,82 % (f)	0,69 % (f)	0,69 % (f)	0,72 % (f)	0,76 % (f)	0,72 % (f)	0,76 % (f)	0,76 % (f)
30.11.2020 12:26:55 409мсек	ТНД тока	6,65 % (f)	9,88 % (f)	21,09 % (f)	3,15 % (f)	6,25 % (f)	13,99 % (f)	7,81 % (f)	10,37 % (f)	16,33 % (f)	10,37 % (f)	16,33 % (f)	16,33 % (f)
30.11.2020 12:26:55 409мсек	К-фактор А	1,58 (f)	1,93 (f)	2,46 (f)	1,51 (f)	1,8 (f)	2,45 (f)	1,47 (f)	1,71 (f)	2,13 (f)	1,71 (f)	2,13 (f)	2,13 (f)
30.11.2020 12:26:55 409мсек	ТНД мощности	0,02 % (f)	0,04 % (f)	0,1 % (f)	0 % (f)	0,01 % (f)	0,03 % (f)	0,02 % (f)	0,03 % (f)	0,03 % (f)	0,03 % (f)	0,07 % (f)	0,07 % (f)
30.11.2020 12:26:55 409мсек	К-фактор W	0,99 (f)	1 (f)	1,02 (f)	0,99 (f)	1 (f)	1,01 (f)	1 (f)	1,01 (f)	1,01 (f)	1,01 (f)	1,02 (f)	1,02 (f)
30.11.2020 12:26:55 409мсек	Частота	50,007 Hz (f)	50,012 Hz (f)	50,024 Hz (f)	50,024 Hz (f)	50,024 Hz (f)	50,024 Hz (f)	50,024 Hz (f)	50,024 Hz (f)	50,024 Hz (f)	50,024 Hz (f)	50,024 Hz (f)	50,024 Hz (f)
30.11.2020 12:27:55 409мсек	Уptime рн-рн	127,776 кВ (f)	128,018 кВ (f)	128,216 кВ (f)	128,678 кВ (f)	128,81 кВ (f)	128,92 кВ (f)	128,062 кВ (f)	128,172 кВ (f)	128,271 кВ (f)	128,062 кВ (f)	128,172 кВ (f)	128,271 кВ (f)

